



## RT 0-30 ROOM THERMOSTAT

Item no. 5151

Document type: **Product card**

Document date: **2019-06-24**

Generated by: **Systemair Online Catalogue**

### Description

The RT 0-30 is an electronic room thermostat for indoor wallmounting, with a change-over relay for regulating either heating or cooling. It has an integral sensor, but an external sensor such as the TG-K330 or TG-R630 can also be connected to the thermostat. The RT 0-30 can also be used with other external temperature sensors to achieve different temperature range.



### Technical parameters

|   |              |     |
|---|--------------|-----|
| Voltage                                 | 230          | V   |
| Phase                                   | 1            | ~   |
| Frequency                               | 50/60        | Hz  |
| Temperature range of adjustment         | 0-30         | °C  |
| Enclosure class                         | 30           |     |
| Power consumption                       | 1            | W   |
| Permitted range for ambient temperature | 0-50         | °C  |
| Permitted max. ambient humidity [%RH]   | 90           | %RH |
| Circuit-breaking relay                  | 16, 250 V AC | A   |
| Width                                   | 86           | mm  |
| Height                                  | 86           | mm  |
| Depth                                   | 30           | mm  |

### Accessories

#### Electric accessories

[TG-K360 Duct sensor 0-60°C \(4846\)](#)

[TG-K330 Duct Sensor 0-30°C \(5160\)](#)

[TG-K350 Duct Sensor 20-50°C \(5161\)](#)

[TG-R630 External sensor \(5164\)](#)

#### Get In Touch



Call: [0845 6880112](tel:08456880112)




Email: [info@adremit.co.uk](mailto:info@adremit.co.uk)

#### Our Address

Puravent, Adremit Limited, Unit 5a, Commercial Yard,  
Settle, North Yorkshire, BD24 9RH

## Wiring

...



## Documentation

 [RT\\_IMO\\_GB\\_SE\\_DE.pdf](#) (289,94kB)

 [Decl. of Conformity RT\\_0-30.PDF](#) (47,72kB)

## Specification text

.

### Get In Touch



Call: [0845 6880112](tel:08456880112)



Email: [info@adremit.co.uk](mailto:info@adremit.co.uk)

### Our Address

Puravent, Adremit Limited, Unit 5a, Commercial Yard,  
Settle, North Yorkshire, BD24 9RH